



ÜNKA KABLO

Declaration of Performances (DoP)

No. 20170003

Product Type

LIYCY (300/500 V)

* 2 to 34 core - 0,5 mm²
* 2 to 34 core - 1,5 mm²
* 2 to 5 core - 6 mm²
* 3 to 5 core - 25 mm²
* 3 to 4 core - 70 mm²

* 2 to 34 core - 0,75 mm²
* 2 to 34 core - 2,5 mm²
* 2 to 5 core - 10 mm²
* 3 to 5 core - 35 mm²

* 2 to 34 core - 1,00 mm²
* 2 to 7 core - 4 mm²
* 2 to 5 core - 16 mm²
* 3 to 5 core - 50 mm²

Batch or Serial Number

M1 4 XXX XXYYYYZZ

Intended use:

LIYCY cables are used wiring of measuring instruments, switch cabinets, electrical components, transmitters and receivers, in EMC-sensitive environments with the objective of limiting spread of fire and smoke and subject to regulations on reaction to fire

System 3

of assessment and verification of constancy of performance

Notified laboratory body No. NB 1014

performed the determination of product type on basis of type testing (based on sampling carried out by the manufacturer), type calculation, tabulated values or descriptive documentation of the product and issued the certificate of constancy of performance Factory production control (FPC) carried out by the ÜNKA KABLO as manufacturer

Reaction to fire:

Eca

Harmonized technical
specification

EN 50575 : 2014 / A1:2016
EN 60332-1 & DIN VDE 0812

Dangerous Substances:

NPD

Manufacturer:

ÜNKA KABLO SAN. VE TİC. A.Ş
Saray Mah.
Ahmet Tevfik İleri Cad.
No : 16/4
Ümraniye / İstanbul / TURKEY

Signed for and behalf of the manufacturer by:

Barış TABAK / QA & QC Manager
İstanbul, 17/02/2017



This declaration of performance is issued under the sole responsibility of the manufacturer.