



ÜNKA KABLO

## Declaration of Performances (DoP)

No. 20170004

Product Type

LIYCY-TP (300/500 V)

\* 1 PR to 20PR - 0,5 mm<sup>2</sup>

\* 1 PR to 20PR - 0,75 mm<sup>2</sup>

\* 1 PR to 20PR - 1,00 mm<sup>2</sup>

\* 1 PR to 30PR - 1,5 mm<sup>2</sup>

\* 1 PR to 12PR - 2,5 mm<sup>2</sup>

Batch or Serial Number

M1 4 XXX XXYYYYZZZ

Intended use:

LIYCY-TP cables are used multifunctional in electronics of computer systems, electronic control equipment, office machines, balances, etc. dry or damp rooms with the objective of limiting spread of fire and smoke and subject to regulations on reaction to fire

### System 3

of assessment and verification of constancy of performance

### Notified laboratory body No. NB 1014

performed the determination of product type on basis of type testing (based on sampling carried out by the manufacturer ), type calculation, tabulated values or descriptive documentation of the product and issued the certificate of constancy of performance Factory production control (FPC) carried out by the ÜNKA KABLO as manufacturer

**Reaction to fire:**

**Eca**

Harmonized technical  
specification

EN 50575 : 2014 / A1:2016  
EN 60332-1 & DIN VDE 0812

**Dangerous Substances:**

**NPD**

Manufacturer:

ÜNKA KABLO SAN. VE TİC. A.Ş  
Saray Mah.  
Ahmet Tevfik İleri Cad.  
No : 16/4  
Ümraniye / İstanbul / TURKEY

Signed for and behalf of the manufacturer by:

Barış TABAK / QA & QC Manager  
İstanbul, 17/02/2017



This declaration of performance is issued under the sole responsibility of the manufacturer.