



ÜNKA KABLO

Declaration of Performances (DoP)

No. 20170051

Product Type

YY-LSOH / HMH / HSLH (300/500 V)

* 2 to 34 core - 0,5 mm²
* 2 to 34 core - 1,5 mm²
* 2 to 5 core - 6 mm²
* 3 to 5 core - 25 mm²

* 2 to 34 core - 0,75 mm²
* 2 to 34 core - 2,5 mm²
* 2 to 5 core - 10 mm²
* 3 to 5 core - 35 mm²

* 2 to 34 core - 1,00 mm²
* 2 to 7 core - 4 mm²
* 2 to 5 core - 16 mm²

Batch or Serial Number

M1 2 XXX XXYYZZZ

Intended use:

YY-LSOH / HMH / HSLH cables are used as supply of electricity and communications in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke

System 1+

of assessment and verification of constancy of performance

Notified laboratory body & Certificate No. NB 1783

performed the determination of product type on basis of type testing (based on sampling carried out by the manufacturer), type calculation, tabulated values or descriptive documentation of the product and issued the certificate of constancy of performance. Factory production control (FPC) carried out by the ÜNKA KABLO as manufacturer

Reaction to fire:

CcaS1d0a1

Harmonized technical specification
EN 50575 : 2014 / A1:2016
EN 50399 & EN 61034-2 &
EN 50267-2-3 & EN 60332-1-2 &
EN 50525-3-11

Dangerous Substances:

NPD

Manufacturer:

ÜNKA KABLO SAN. VE TİC. A.Ş.
Saray Mah.
Ahmet Tevfik İleri Cad.
No : 16/4
Ümraniye / İstanbul / TURKEY

Signed for and behalf of the manufacturer by:

Barış TABAK / QA & QC Manager
İstanbul, 01/06/2017


ÜNKA KABLO
SANAYİ ve TİCARET A.Ş.
ÜMRANIYE - İSTANBUL

This declaration of performance is issued under the sole responsibility of the manufacturer.