

Camignone di Passirano 01/02/2018

**DECLARATION OF PERFORMANCE**  
**No. DoP 00001**

**Unique identification code of the product-type**

H1Z2Z2-K I Sect. 4 mm<sup>2</sup> - 6 mm<sup>2</sup> - 10 mm<sup>2</sup>

**Intended use**

Power, control and communication cables – Cables for general application in construction works subjected to reaction to fire requirements

**Producer**

Elettro Brescia S.p.A.  
Via Bulloni 36  
I – 25050 Camignone di Passirano (BS)

**AVCP SYSTEM**

3

**Harmonized Standard**

EN 50575:2014 + A1:2016

**Notified Body**

2479 – L.S. Fire Testing Institute S.r.l.

**Agent**

N.A.

**Declared performance**

Fire Reaction: Dca – s2,d2,a1

Dangerous substances: none

This declaration of performance is issued under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

Marco Del Corno  
Quality and Laboratory Manager

