

Camignone di Passirano 01/02/2018

## DECLARATION OF PERFORMANCE No. DoP 00001

## Unique identification code of the product-type

H1Z2Z2-K I Sect. 4 mm<sup>2</sup> - 6 mm<sup>2</sup> - 10 mm<sup>2</sup>

## Intended use

Power, control and communication cables – Cables for general application in construction works subjected to reaction to fire requirements

**Producer** Elettro Brescia S.p.A. Via Bulloni 36 I – 25050 Camignone di Passirano (BS)

AVCP SYSTEM 3

Harmonized Standard EN 50575:2014 + A1:2016

**Notified Body** 2479 – L.S. Fire Testing Institute S.r.l.

Agent N.A.

**Declared performance** Fire Reaction: Dca – s2,d2,a1 Dangerous substances: none

This declaration of performance is issued under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

Marco Del Corno Quality and Laboratory Manager

Morros Jelbur